

Bill No. 2023-23

Ordinance No. 23-23

AN ORDINANCE TO AMEND SECTION 500.090 ADDITIONS, INSERTIONS, CHANGES OF THE CODE OF THE CITY OF HOLLISTER, MISSOURI.

BE IT ORDAINED BY THE BOARD OF ALDERMEN OF THE CITY OF HOLLISTER, MISSOURI AS FOLLOWS:

Section 500.090. Additions, Insertions, Changes.

The following Sections of the National Electric Code are hereby revised as follows:

Amended Section 334.12 Uses Not Permitted (B) Types NM and NMS: Types NM and NMS (non-metallic sheathed) cables shall not be used under the following conditions or in the following locations:

READ THIS FIRST AND SECOND TIME AND PASSED BY THE BOARD OF ALDERMEN OF THE CITY OF HOLLISTER, MISSOURI THIS 3RD DAY OF AUGUST, 2023.

Lamar Patton, Mayor

ATTEST:

Bridget Epps, City Clerk

STAFF REPORT FOR PLANNING COMMISSION

Prepared by Kathy Knight

TO: Rick Ziegenfuss, City Administrator

DATE: July 11, 2023

SUBJECT: Amendment to Section 500.090 Additions, Insertions, Changes.

Information: The staff is updating our 2017 National Electrical Code (NEC) to 2023 NEC. We need to update our Additions, Insertions, Changes to meet 2023 NEC in wording and section reference. The Additions, Insertions, Changes shall take effect on August 4, 2023, as we adopt 2023 NEC.

The staff is deleting #5, the reason is that #4 clearly states not to be used in wet or damp locations.

Deleted wording is shown in ~~striketrough~~ print and added wording is in **bold underlined** print.

Section 500.090. Additions, Insertions, Changes.

[Ord. No. 94-37 §47.020(4), 8-4-1994; Ord. No. 97-10 §500.090, 8-7-1997; Ord. No. 01-06, 2-1-2001; Ord. No. 04-04, 2-19-2004; Ord. No. 06-37, 9-7-2006; Ord. No. 11-12, 8-4-2011; Ord. No. 12-05, 2-2-2012; Ord. No. 18-34, 4-19-2018]

The following Sections of the National Electric Code are hereby revised as follows:

Amended Section 334.12 Uses Not Permitted (B) Types-NM and NMS: Types NM and NMS (non- metallic sheathed) cables shall not be used under the following conditions or in the following locations:

~~**"(5) Where the wiring will be below the elevation of the designated Base Flood Elevation (floodplain) on the current FIRM maps."**~~

The Staff recommends approval of this request.

Planning Commission recommends this forward.