

BILL NO. 12

ORDINANCE NO. 2024-12


AN ORDINANCE OF THE CITY OF TRENTON, MISSOURI APPROVING A PROPOSAL BY AND BETWEEN THE CITY OF TRENTON, MISSOURI, AND SMICO CONTRACTING GROUP, LLC FOR THE RECONSTRUCTION OF THE PAUPER GRADE SEWER LIFT STATION AND AUTHORIZING THE MAYOR AND CITY CLERK OF THE CITY OF TRENTON, MISSOURI, TO EXECUTE THE SAME BY AND ON BEHALF OF SAID CITY.

BE IT ORDAINED, BY THE CITY COUNCIL OF THE CITY OF TRENTON, MISSOURI, AS FOLLOWS, TO WIT:


Section 1. The Mayor and City Clerk of the City of Trenton, Missouri, are hereby authorized and directed to execute said Proposal, between Smico Contracting Group, LLC and the City of Trenton in and on behalf of the City of Trenton, Missouri. Said proposal is attached to this Ordinance as Exhibit A.

Section 2. This Ordinance shall be in full force and effect immediately from and after its passage and approval.

PASSED this 25th day of March, 2024.


MAYOR AND EX OFFICIO PRESIDENT OF
THE CITY COUNCIL OF THE CITY OF
TRENTON, MISSOURI


ATTEST:


CITY CLERK

APPROVED this 25th day of March, 2024.


MAYOR OF THE CITY OF TRENTON,
MISSOURI

FILED this 25th day of March, 2024.


CITY CLERK

SMICO CONTRACTING GROUP, LLC

PROPOSAL

March 6, 2024

PROJECT: Trenton Lift Station

LOCATION: Trenton, MO

To: City of Trenton Attention: Bob Hutchinson

SMI-CO Contracting Group LLC proposes to provide the following as specified below for the above referenced project.

Bid Includes:

- Provide and Install new 6' diameter x 16' deep wetwell (within 10' of existing)
- Excavation and backfill provided
- Provide and Install USEMCO Pumpmate, 2 Homa pumps, and appurtenances
- Provide and Install all piping (sch. 80 PVC)
- Convert existing wetwell to transfer manhole (core drill new line to wetwell)
- Tie in to existing force main
- Demo existing pumps and piping
- Electrical as required for new control panel and pumps
- Provide and Install new 150 amp main breaker

Bid Excludes:

Taxes, Bonds, permits, bypass pumping, fence, rock excavation, dewatering (if excess ground water is encountered), anything not expressly listed above.

Total..... \$239,247.00

Adder: Install 2 soft starters in control panel.....\$5,133.00

Thank you for considering our proposal for this project.
Quote is valid 30 days from bid date

Submitted by _____
Darryl R. Smith, President

Accepted by: _____

P.O. Box 563, Odessa, MO-64076 (Office) 816-229-2244 (Fax) 816-697-1816