

WATER AND SEWER

*700 Attachment 2*

**City of Billings**

**EXHIBIT 2**

**Types of Facilities Representing Low-Hazard Cross-Connections  
[Ord. No. 14-08 §XI, 2-13-2014]**

1. Tanks to store water from the public water system for fire fighting only, unless the tanks meet the requirements of the department for construction to maintain bacteriological quality of the water;
2. Fire sprinkler systems not using chemical additives. This only applies to new fire sprinkler systems or fire sprinkler systems scheduled for modifications;
3. Irrigation systems without facilities for injection of pesticides or other chemicals. The backflow prevention assembly may be installed between the customer service line and the irrigation system; and
4. Cross-connections that could permit introduction of contaminants into the public or customer water system and create a nuisance, be aesthetically objectionable, or cause minor damage to the water distribution system or its appurtenances.