

WATER

126 Attachment 2

EXHIBIT B

Table 1
Separation Distances From Community Water Supply Wells¹
Wellhead Protection Plan

Potential Contamination Source	Minimum Separation Distance (feet)
Storm sewer main	50
Sanitary sewer main	200
Lift station	200
Single-family residential fuel oil tank	200
Septic tank (less than 8,000 gallons per day)	400
Cemetery	400
Stormwater drainage pond	400
Gasoline or fuel oil storage tank installation (DILJD approved)	600
Land application of municipal, commercial or industrial waste	1,000
Industrial, commercial or municipal wastewater lagoons or storage structures	1,000
Manure stacks or storage structures	1,000
Septic tanks (greater than 8,000 gallons per day)	1,000
Solid waste storage, transportation, transfer, incineration, air curtain destructor, processing, wood burning, one-time disposal or small demolition facility	1,200
Sanitary landfill	1,200
Coal storage area	1,200
Salt or deicing material storage area	1,200
Gasoline or fuel oil storage tank without DILJD approval	1,200
Bulk fuel storage facilities	1,200
Pesticide or fertilizer handling or storage facilities	1,200

NOTES:

¹Wisconsin Administrative Code Section NR 811.16(4)(c), April 1992.