

SEWERS AND SEWAGE DISPOSAL

18 Attachment 1

Township of New Hanover

EXHIBIT 18-A

EDU SCHEDULE

[Ord. 97-1, 5/12/1997, Exhibit "A"]

Property to be Connected	EDU Value
1. Each private dwelling or living unit	1 EDU/Unit
2. Each hotel, motel or boarding house	
a. Without kitchen and/or laundry facilities in unit	1 EDU/2.5 suites
b. With kitchen and/or laundry facilities in unit	1 EDU/1.75 suites
c. With kitchen and/or laundry facilities in unit and more than 1 bedroom	1 EDU/suite
3. Each restaurant, club or tavern	
a. Toilet and kitchen wastes	1 EDU/7 seats
b. Additional for bars and cocktail lounges	1 EDU/14 seats
c. Kitchen and toilet waste, single-service utensils	1 EDU/connection
4. Each church (not including daycare or social halls)	1 EDU/connection
5. Each fire company (not including social halls)	1 EDU/connection
6. Each municipal building	1 EDU/connection
7. Each service station, automobile repair shop or garage	1 EDU/restroom
8. Each barber or beauty shop	1 EDU/2 chairs
9. Each retail or wholesale store	1 EDU/3,500 square feet
10. Each enclosed shopping mall, open air shopping or commercial shopping center	1 EDU/2,200 square feet
11. Each grocery market, supermarket, convenience store without in-store food service	2 EDUs/10 employees
12. Each office, office building or portion of a building used for office or professional space	1 EDU/3,500 square feet
13. Each doctor's office	1 EDU/2 examining rooms
14. Each dentist's office	1 EDU/3 dental chairs
15. Each industry (excluding process waste)	1 EDU/3,500 square feet
16. Each public or private day school employees and pupils	1 EDU/20 teachers, employees and pupils
17. Each day care school or nursery school	1 EDU/20 teachers, employees and pupils
18. Each self-service laundromat	2 EDUs/machine
19. Each car wash	2 EDUs/first bay 1 EDU/each additional bay
20. Each warehouse	1 EDU/25,000 square feet
21. Industrial process waste or any wastewater	1 EDU/200 gpd of water

NEW HANOVER CODE

Property to be Connected	EDU Value
discharge other than norm domestic waste	consumption
22. Each meal caterer, where all meals are served on the premises	
a. Where all meals are served on the premises	1 EDU/30 seats (seating capacity)
b. Where all meals are served off the premises	1 EDU/2,500 square feet
23. Each general hospital	1 EDU/1.5 beds
24. Each rest home, nursing home	1 EDU/2.5 beds
25. Each funeral home	1 EDU/2 viewing rooms
26. Each theater	1 EDU/100 seats
27. Each bowling alley	1 EDU/5 alleys
28. Any other uses not classified above	To be determined by the Township

ADDITIONAL CONDITIONS

1. Where two or more buildings are connected to the sewer system through a single service connection or where two or more uses are made of the same improved property (i.e., motel with a restaurant, retail store with a restaurant, home with a professional office, etc.), the EDU determination shall be computed as though such building and each type of use were separate improved properties or uses with separate sewer connections.
2. For purposes of this EDU Schedule, meal caterers shall be defined as any business which prepares and serves food only for prearranged social gatherings, but does not maintain regular meal serving hours and does not serve meals to the general public. For meal caterers that serve meals both on and off premises, the higher of the two EDU values computed by Item 22 above shall be the EDU value used to compute the tapping fee.
3. Where square footage is used to determine tapping fee EDU values, the gross floor area of the building shall be used.
4. When computing EDU values as per the above schedule, no partial EDUs will be permitted. All values will be rounded up to the next whole value.
5. The EDU values above are based on an allowance of 200 gallons per day of water use per EDU plus an average infiltration/inflow allowance. Capacity allocations shall be determined on the basis of a total wastewater flow (including water use and a reasonable infiltration/inflow allowance) of 275 gallons per day per EDU. Should the volume of water used over any quarterly period exceed an average of 200 gallons per day per EDU, the property owner shall be assessed an additional EDU for the additional use at the values specified herein. Upon assessment of the additional EDU(s), the Township shall adjust the EDU value of the property on its records. Once an EDU value has been assessed, it will not be decreased for wastewater discharges less than the allowable.