

WATER AND SEWERS

415 Attachment 2

Charter Township of Oakland

**Appendix B
Phenolic Compounds**

An industrial user may elect, in lieu of the total phenols limitation specified in § 415-21B(2)(b), to substitute specific limitations for each of the eight individual phenolic compounds identified under the total phenols limitation. The following specific limitations, expressed in mg/l, shall be applied in lieu of the total phenols limitation, upon election:

2-Chlorophenol	2.0 mg/l
4-Chlorophenol	2.0 mg/l
4-Chloro-3-methylphenol	1.0 mg/l
2,4-Dichlorophenol	5.5 mg/l
2,4-Dinitrophenol	2.0 mg/l
4-Methylphenol	5.0 mg/l
4-Nitrophenol	15.0 mg/l
Phenol	14.0 mg/l

Following election, the wastewater discharge permit shall be modified to incorporate these substituted parameters and an industrial user shall be responsible for monitoring and reporting compliance with these parameters.