

WATER AND SEWERS

415 Attachment 3

Charter Township of Oakland

Appendix C Interim Discharge Limitations

No user shall discharge wastewater containing any of the following pollutants in excess of the following interim pollutant discharge limitations:

- (1) Compatible pollutants:
 - a. Any fats, oil or grease (FOG) in concentrations greater than 1,500 mg/l based on an average of all samples collected within a twenty-four-hour period.
 - b. Any total suspended solids (TSS) in concentrations greater than 7,500 mg/l.
 - c. Any biochemical oxygen demand (BOD) in concentrations greater than 7,500 mg/l.
 - d. Any phosphorus (P) in concentrations greater than 250 mg/l.

Unless otherwise stated, all limitations are based upon samples collected over an operating period representative of a user's discharge, and in accordance with 40 CFR 136.

- (2) Noncompatible pollutants: Cadmium (Cd) 1.0 mg/l.