

Model Local Law Regulating Disposal of Wastewater

Engineer Rathbone stated that at some point in the near future, the Village Board will have to adopt a local law regulating the disposal of wastewater, the construction of use of public sewers, building sewers, and the discharge of waters and wastes in the public sewer and providing penalties for the violation in the Village of Hamilton.

Village Clerk J. Morgan handed out to the Village Board a model local law with regard to this matter from EPA.

Deletion of I/I Corrections - Project C-36-1178-04-0

Engineer Rathbone stated that the Village has submitted a grant application for federal and state aid in the amount of \$600,000 for infiltration/inflow (I/I) corrections. Engineer Rathbone stated that he has been advised by the NYSDEC that the I/I correction work has a low priority rating and must await completion of the final Sewer System Evaluation Study (SSES). Normal procedure would be to delay all wastewater treatment plant upgrading work until completion of the final SSES and I/I corrections. Because of the low national priority for I/I corrections, the WWTP upgrading may not be funded for several years, at which time the federal funding level will drop from 75% to 55%.

MUC President E. Hotaling stated that he met with Stearns & Wheler and Village Engineer J. Rathbone to discuss the project. Mr. Hotaling stated that Stearns & Wheler has assured us that the proposed plant can handle a flow of 2.3 million gallons per day. Mr. Hotaling stated that Stearns & Wheler recommends dropping the I/I correction project to avoid jeopardizing the funding changes for the WWTP upgrading project. Mr. Hotaling stated that Mr. Wheler does not foresee any problems treating the infiltration and inflow at the plant.

Engineer Rathbone stated that the MUC adopted a resolution recommending that the Trustees delete the infiltration and inflow correction project from the NYS Priority List.

It was moved by C. Getchonis and seconded by D. Ray to submit a request to the NYSDEC to delete the infiltration and inflow correction project from the NYS Priority List. The motion carried unanimously.

On motion, meeting adjourned.

James P. Morgan
Village Clerk

July 6, 1983

The following bids were opened in response to Bid Specification 5-83, Street Reconstruction and Paving, Various Areas at 8:15 a.m. on July 6, 1983 at the Village Office. Present were Trustee Arnold Fisher, Engineer J. Rathbone and Clerk J. Morgan

Bid Opening - Bid 5-83

	<u>Ruston Paving Co. Jamesville, NY</u>	<u>Solid Seal Systems, Inc. Apalachin, NY</u>	<u>Davis Wallbridge E. Syracuse, N.Y.</u>
<u>Bid Item #1</u>			
University Ave. 6" Cement Stabilized Base	\$ 9.00 sq.yd.	\$ 7.85 sq.yd.	\$10.00 sq.yd.
University Ave. Asphalt Concrete Top Course	\$ 3.60 sq.yd.	\$ 3.15 sq.yd.	\$ 3.25 sq.yd.
<u>Bid Item #2</u>			
Madison and Hamilton Sts. 8" Cement Stabilized Base	\$10.00 sq.yd.	\$ 8.95 sq.yd.	\$10.00 sq.yd.
Madison and Hamilton Sts. Asphalt Concrete Top Course	\$ 3.60 sq.yd.	\$ 3.15 sq.yd.	\$ 3.25 sq.yd.
<u>Bid Item #3</u>			
Repair Utility Cuts, NYS Route 12B	\$36.00 sq.yd.	\$65.00 sq.yd.	\$180.00 sq.yd.